

Letter No. 741

Date 24/02/2024

P.H. Division, Buxar
Water Quality Monitoring Report

District Name: BUXAR

Division Name: BUXAR

Sl. No	Block	Panchyat	Village	Location of Source	Parameters															Remarks
					PH	Turb.	EC	TDS	TH	Ca	Mg	Cl	Alka.	Fe	NO ₃	SO ₄	F	As	Total Coli	
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21
1	BUXAR	NADAON	LALGANJ	D.A.V. PUBLIC SCHOOL	7.5	2	664.0	432	220.0	64.0	37.0	30	280	0.2	25	20.0	0.6	BDL	Negative	-
UNIT						NTU	µmho/cm	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	-	
Desirable Limit*					6.5-8.5	5.0	-	500	200	75	30	250	200	0.3	45	200	1.0	0.01	-	
max. permissible limit					NR	NR	-	2000	600	200	100	1000	600	1.0	NR	400	1.5	NR	-	

Remark: Water is fit for drinking.

[Signature]
Chemist
24/2/2024
P.H. Division, Buxar

[Signature]
24/02/2024
Executive Engineer
P.H. Division, Buxar